

Monitoring Violations Annual Notice Template

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for IL0730450

Our water system violated one drinking water standard over the past year. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 8/1/2025-8/31/2025 our certified third-party laboratory lost our timely submitted samples, causing a resample in which those results were not submitted to the Illinois EPA by the 10th of the month following the monitoring period for Disinfection By-Products (DBP). Our samples were reported to the Illinois EPA later than the deadline; however, results met the guidelines.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for total haloacetic acids, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Table with 5 columns: Contaminant, Required sampling frequency, Number of samples taken, When all samples should have been taken, When samples were or will be taken. Row 1: Total Haloacetic Acids (HAA5), TTHM, Yearly, 1, 8/1/2025-8/31/2025, 9/15/2025.

What happened? What is being done?

Our certified third-party laboratory lost our timely submitted samples, causing a resample in which those results were not submitted to the Illinois EPA by the 10th of the month following the monitoring period for Disinfection By-Products (DBP). Our samples were reported to the Illinois EPA later than the deadline; however, results met the guidelines.

Per Pace Analytical Services, LLC: METHOD 552 (HAA) WAS CANCELLED DUE TO INTERNAL STANDARD FAILURES AND THE SAMPLE BEING OUT OF HOLD TO RE-EXTRACT. CLIENT WAS CONTACTED AND RESAMPLE BOTTLES REQUESTED.

For more information, please contact Jacob McClintic at 309-932-2555 or 311 NW 4th Ave, Galva, IL 61434

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.